

SIDE ELEVATION



END ELEVATION



GENERAL SPECIFICATIONS

1. ORDER QUANTITY: 1 TANK
2. NOMINAL CAPACITY: 8,000 GALLONS
3. VESSEL OPERATING PRESSURE: ATMOSPHERIC
4. VESSEL OPERATING TEMPERATURE: AMBIENT
5. CONSTRUCTION: DOUBLE-WELDED BUTT JOINT
6. MATERIAL: MILD CARBON STEEL
7. TEST: PER UL58
8. APPROVED LABELS: UL58, STI PERMATANK
9. EXTERIOR COATING: SANDBLAST AND 102 MILCERTANTEED 298 EXTERIOR
10. INTERIOR COATING: DEF PHENICON
11. ALL FITTINGS TO BE STAINLESS STEEL

GENERAL DIMENSIONS

CAPACITY	DIAMETER	LENGTH	WEIGHT
8,000 GAL	8"	21'-6"	9,601 LBS

GAUGE/THICKNESS

OUTER HEAD	OUTER SHELL	INNER HEAD	INNNER SHELL
12 GA	12 GA	12 GA	12 GA

FITTING DETAIL

TAG NO.	DESCRIPTION	LOCATION	NOZZLE SIZE
N1	FILL	TOP	4" FNPT
N2	GAUGE	TOP	4" FNPT
N3	INTERSTITIAL GAUGE	TOP	2" FNPT
N4	GAUGE	TOP	4" FNPT
N5	GAUGE	TOP	4" FNPT
N6	GAUGE/VENT	TOP	4" FNPT
N7	GAUGE/VENT	TOP	4" FNPT
M1	REVERSE MANWAY	TOP	24" FNPT

NO.	REVISION/ISSUE	DATE

CUSTOMER INFORMATION

8000 GAL DWPT DEF

DRAWN BY:	CRP	DRAWING NUMBER:	TANK #1
REVIEWED BY:	MEJ	DRAWING DATE:	06/14/14
SCALE:	NTS	QUOTE NUMBER:	8000 GAL DEF

CAD FILE NAME:

8000 GAL DWPT DEF.DWG

acterra GROUP
Corporate Centre 200
PO Box 160
Marion, IA 52302-0160
T 319.377.6357
F 319.377.0075
www.acterragroup.com
Info@acterragroup.com

DISCLAIMERS

THIS DRAWING IS THE PROPERTY OF ACTERRA GROUP, INC. AND IS SUBMITTED AS A CONFIDENTIAL DISCLOSURE. ALL RIGHTS TO REPRODUCE THIS DRAWING AND THE ARTICLES THEREIN ARE EXPRESSLY RESERVED. THIS DOCUMENT AND ITS CONTENTS SHALL BE CONSIDERED INTELLIGENT PROPERTY OF THE ACTERRA GROUP, INC.. THEREFORE, THE USE OF THE DOCUMENT AND ITS CONTENTS ARE STRICTLY PROHIBITED WITHOUT THE WRITTEN APPROVAL OF THE ACTERRA GROUP, INC.. THE SIZES, DIMENSIONS, THICKNESS, ETC.. ARE NOT INTENDED TO REPLACE OR REPRESENT NECESSARY ENGINEERING CALCULATIONS. THE SIZES, DIMENSIONS, THICKNESS, ETC.. ARE NOT TO SUPERSEDE EXISTING TANK LAWS, REGULATIONS OR STANDARDS.

APPROVAL

CUSTOMER: _____

DATE: _____

FNAME

REVDATE

USER